



ADDENDUM #1

REQUEST FOR PROPOSALS

RFP-09-23 Hoskyn Channel Landing Float and Gangway Replacement

Issued December 1, 2023

The Strathcona Regional District (SRD) wishes to issue the following addendum to RFQ 09-23 – Hoskyn Channel Landing Float and Gangway Replacement.

Question:

How wide is the proposed new ramp?

Response:

The new gangway ramp should be designed to have a clear width between handrails of 1000mm. The ramp should be designed to suit the existing trestle, which is 1524mm wide. The contractor will be responsible for detailed design of all components, including the gangway ramp and proposed connection to the existing trestle.

Please sign below, acknowledging receipt of this Addendum and return this document with your submission to the RFP.

Signature

Name of Firm

Name and Title (Print)

Date